

VNIV2.EX3948 - Sprinklers, Automatic and Open - Component

Sprinklers, Automatic and Open - Component

See General Information for Sprinklers, Automatic and Open - Component

DAY-IMPEX LTD
STATION WORKS
EARLS COLNE
COLCHESTER, ESSEX CO6 2ER UNITED KINGDOM
Glass bulb heat-responsive element

EX3948

Model	Temperature Rating, °F
Style 937	135, 155, 175, 200, 286
Style 941	155, 175, 200

Marking: Company name, model or style designation and the Recognized Component Mark .

Last Updated on 2007-05-16

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"

Search Results

You are here: [Home](#) » Search Results

Automatic sprinkler, water spray and deluge systems

Automatic sprinkler, water spray & deluge systems

Day-Impex Limited

Station Works
Earls Colne
Colchester
Essex
CO6 2ER
United Kingdom

Tel: +44 (0)1787 223232 • Fax: +44 (0)1787 224171
Web: www.day-impex.co.uk

Certificate No 291a

Product	Bulb Size (mm)	Temperature Rating (°C)	LPCB Ref. No.
937	5	57, 68, 79, 93, 141, 182	291a/02

[To read the Red Book section introduction click here.](#)

[< back to results page](#)

[< back to search page](#)

