



Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
<http://www.apragaz.com>
info@apragaz.com



EU TYPE EXAMINATION CERTIFICATE – Production Type In accordance with the requirements of Module B of the Pressure Equipment Directive 2014/68/EU		Certificate N° 19/FR/4525-1-REV.0
Manufacturer	Name	REFLEXOFEU SASU
	Address	2 l'érable, 28250 Digny France
Concerned Equipment: Automatic fire extinguishing detection system for Electrical & IT cabinets Types: • REFLEX-1L-2L-3L-6L-9L : 1l-2l-3l-6l-9l Foam • REFLEX-1K-2K-3K-6K-9K : 1kg-2kg-3kg-6kg-9kg Powder ABC • REFLEX-1N-2N-3N-6N-9N : 1kg-2kg-3kg-6kg-9kg FK-5-1-12 Clean Agent acc. to Technical File REFLEXOFEU version C (12/10/2021) Capacity: 1-2-3-6-9kg (powder & FK-5-1-12 Clean Agent) & 1-2-3-6-9l (foam) Design Pressure Ps : 18 bar Service Pressure at 20°C : 15 bar Test pressure cylinder: minimum 30 bar Opening pressure safety device : 21 – 26 bar Service temperature range: min. -30 °C / max. +60 °C (powder & FK-5-1-12 Clean Agent) & min. +5 °C / max. +60 °C (foam)		
The manufacturer is allowed to affix the « CE » mark followed by the notified body number to the approved equipment under the conditions described in article 19 of the Directive and only if the requirements stated in module D or C2 are fully met. The approval is valid until 02/06/2029 APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/68/EU, certifies that the design of these pressure assemblies conforms to the relevant requirements of the Pressure Equipment Directive 2014/68/EU on basis of the documentation and samples supplied for review and approval.		
Approval Date : 06/04/2022	Name : Ir. B. NEVE,	Position General Manager
Notified body identification number : 0029		Signature 
Notified body:	APRAGAZ VZW / ASBL	 F. LOURTIE Chief Accountant
Notified body reference :	17762P000	